

TEST REPORT Nº 1189/2020

Date – 29/05/2020

CUSTOMER NAME: DIGIDELTA INTERNACIONAL IMPORT EXPORT, SA

ADDRESS: 2350-483 TORRES NOVAS

Sample Name: DECAL OVERLAMINATED P HT 100 FLOORGRAPHIC

Material and Mark: PVC adhesive film

Above information and sample(s) was/were submitted and confirmed by the client. CTCV, however, assumes no responsibility to verify the accuracy, adequacy and completeness of the sample information provided by client.

Test Required: Slip resistance (oil-wet ramp test)

Test Method: DIN 51130:2014

Date of Receipt: 15/05/2020

Testing Start Date: 28/05/2020

Testing End Date: 28/05/2020

Test result(s): For further details, please refer to the following page(s)
(Unless otherwise stated the results shown in this test report refer only to the sample(s) tested)

Signed for

CTCV / Testing Materials Laboratory



Joaquim Valente de Almeida

Os resultados apresentados neste trabalho referem-se apenas às amostras ensaiadas. Os resultados aplicam-se à amostra conforme rececionada. Não se assume qualquer responsabilidade relativa à exatidão da amostragem, a menos que seja eretuada sob a direta responsabilidade do CTCV. A reprodução deste trabalho é autorizada apenas na sua forma integral. Para qualquer reprodução será indispensável autorização do CTCV por escrito.

Test Item: Slip resistance (oil-wet ramp test)

Test Method: DIN 51130:2014 - Testing of floor coverings - Determination of the anti-slip property - Workrooms and fields of activities with slip danger, walking method - Ramp test

Sample Description: flooring (PVC adhesive film)

Test Result:

Testing surface:

Test item(s)	Test result(s)	Classification
Slip resistance (oil-wet ramp test)	Critical angle of inclination: 6.1º	R9

Classification of oil-wet ramp test:

Classification	Angle (degrees)
R9	$6^\circ \leq X \leq 10^\circ$
R10	$10^\circ < X \leq 19^\circ$
R11	$19^\circ < X \leq 27^\circ$
R12	$27^\circ < X \leq 35^\circ$
R13	$> 35^\circ$

***** End of report*****